

2020 Consumer Confidence Report

Water System Name: Los Osos Community Services District

Report Date: February 23, 2021

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 to December 31, 2020 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Los Osos Community Services District a 2122 9th St., Suite 110, Los Osos, CA 93402, (805)528-9370 para asistirlo en español.

这份报告含有关于您的饮用水的重要讯息。请用以下地址和电话联系Los Osos Community Services District以获得中文的帮助: 2122 9th St., Suite 110, Los Osos, CA 93402, (805)528-9370

Ang pag-uulat na ito ay naglalaman ng mahalagang impormasyon tungkol sa inyong inuming tubig. Mangyaring makipag-ugnayan sa Los Osos Community Services District, 2122 9th St., Suite 110, Los Osos, CA 93402 o tumawag sa, (805)528-9370 para matulungan sa wikang Tagalog.

Báo cáo này chứa thông tin quan trọng về nước uống của bạn. Xin vui lòng liên hệ Los Osos Community Services District tại 2122 9th St., Suite 110, Los Osos, CA 93402, (805)528-9370 để được hỗ trợ giúp bằng tiếng Việt.

Tsab ntawv no muaj cov ntsiab lus tseem ceeb txog koj cov dej haus. Thov hu rau Los Osos Community Services District ntawm 2122 9th St., Suite 110, Los Osos, CA 93402, (805)528-9370 rau kev pab hauv lus Askiv.

Type of water source(s) in use: Groundwater Wells

Name & general location of source(s): Los Osos CSD uses six source wells: 8th Street Well, 3rd Street Well, South Bay Lower Aquifer Well, South Bay Upper Aquifer Well, 10th Street Well, and Palisades Well.

Drinking Water Source Assessment information: A source assessment was completed in June 2001. Wells are considered most vulnerable to activities associated with high-density housing, storm water drainage, and agricultural activities.

Time and place of regularly scheduled board meetings for public participation: Public meetings are held at the Los Osos CSD office at 2122 9th Street, Suite 106 on the first Thursday of each month at 6:00 pm

For more information, contact: Margaret Falkner, Utility Systems Manager Phone: (805) 528-9376

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	(In a month) 0	0	1 positive monthly sample	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule)	(In the year) 0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive	0	Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	(In the year) 0	0	(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of Samples Collected	90th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	No. of Schools Requesting Lead Sampling	Typical Source of Contaminant
Lead (ppb)	2020	21	5.4	1/21	15	0.2	0	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	2020	21	0.77	0/21	1.3	0.3	Not applicable	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Lead and Copper sampling is conducted in volunteer homes at kitchen taps in our water system.

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2020	34	24 - 53	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm) Total Hardness as CaCO ₃	2020	160	75 - 313	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Aluminum (ppm)	2020	ND	ND	1	0.6	Erosion of natural deposits; residue from surface water treatment processes
Arsenic (ppm)	2020	ND	ND	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Barium (ppm)	2020	ND	0.09 - 0.13	1	2	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits
Chlorine (ppm)	2020	0.88	<0.10 – 1.29	[4.0 (as Cl ₂)]	[4.0 (as Cl ₂)]	Drinking water disinfectant added for treatment
Total Chromium (ppb)	2019	8.7	<5 – 36	50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Copper (ppm)	2020	ND	ND	(AL=1.3)	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride (ppm)	2020	ND	ND	2.0	1	Erosion of natural deposits; discharge from fertilizer and aluminum factories
HAA5 - Haloacetic Acids (ppb)	2020	3.6	N/A	60	N/A	Byproduct of drinking water disinfection
Heterotrophic Plate Count – HPC (CFU/mL) (Distribution)	2020	3.3	<1 – 16	TT	N/A	Naturally present in the environment
Heterotrophic Plate Count – HPC (CFU/mL) (Well after treatment)	2020	1.9	<1 – 10	TT	N/A	Naturally present in the environment
Lead (ppb)	2020	1.57	<0.5 – 1.3	AL= 15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Nickel (ppb)	2020	<10	<10	100	12	Erosion of natural deposits; discharge from metal factories
Nitrate as Nitrogen, N (ppm)	2020	5.6	3.9 – 7.5	10 (as N)	10 (as N)	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrite as Nitrogen, N (ppm)	2020	0.22	<0.1 – 0.25	1 (as N)	1 (as N)	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Perchlorate (ppb)	2020	ND	<0.5 - <1.0	1	1	Perchlorate is an inorganic chemical used in solid rocket propellant, fireworks, explosives, flares, matches, and a variety of industries. It usually gets into drinking water as a result of environmental contamination from historic aerospace or other industrial operations that used or use, store, or dispose of perchlorate and its salts.

TABLE 4 (CONTINUED) – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

TTHMs – Total Trihalomethanes (ppb)	2020	7.9	N/A	80	N/A	Byproduct of drinking water disinfection
-------------------------------------	------	-----	-----	----	-----	--

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (ppm)	2020	68.5	28 – 157	500	N/A	Runoff/leaching from natural deposits; seawater influence
Iron (ppb)	2020	<10	<10 - 72	300	N/A	Leaching from natural deposits; industrial wastes
Manganese (ppb)	2020	<5	<5 – 7	50	N/A	Leaching from natural deposits
Specific Conductance (µS/cm)	2019	503.5	18 – 840	1,600	N/A	Substances that form ions when in water; seawater influence
Sulfate (ppm)	2020	18.2	2.7 – 48.2	500	N/A	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids – TDS (ppm)	2020	331.0	178 – 512	1,000	N/A	Runoff/leaching from natural deposits
Turbidity (Units)	2020	0.17	0.06 – 0.55	5	N/A	Soil runoff
Zinc (ppm)	2020	0.071	<0.015 – 0.174	5	N/A	Runoff/leaching from natural deposits; industrial wastes

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Hexavalent Chromium (ppb)	2020	3.6	ND – 4.2	1	Some people who drink water containing hexavalent chromium in excess of the MCL over many years may have an increased risk of getting cancer
pH	2020	7.35	7 – 7.51	N/A	Not applicable, Normal constituent

1. There is currently no MCL for hexavalent chromium. The previous MCL of 0.010 mg/L (ppm) was withdrawn on September 11, 2017.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Los Osos CSD is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>